

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1190169

Product: Empty enclosure for switchgear assemblies

Type: RIE

Rating: 600 x 600 x 1645 mm, IP 54

Ordering firm: Tritón Pardubice, spol. s r. o.
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

Manufacturer: Tritón Pardubice, spol. s r. o.
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 910391-01/01 of: 20.02.2019

A sample of the product was found to be in conformity with:
ČSN EN 60529:93+A1:01, ČSN EN 62208 ed. 2:12 cl. 9.8

Other data:

The validity of the certificate is limited to: 31.03.2022

22.03.2019

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



910391-01