

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160610

Product: Empty enclosure for switchgear assemblies

Type: SEF

Rating: IP 55, IK 08, indoor design

Ordering firm: Tritón Pardubice, spol. s r.o.
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

Manufacturer: Tritón Pardubice, spol. s r.o.
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 603612-01/01 of: 12.08.2016

A sample of the product was found to be in conformity with:
ČSN EN 62208 ed.2:12 cl. 4, 6, 6.2, 6.3, 9, 9.3, 9.4, 9.5, 9.7, 9.8, 9.8.1.2, 9.8.2, 9.11, 9.13, 9.13.2.1, 9.13.3, 9.14

Other data:

The validity of the certificate is limited to: 31.08.2019

16.08.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



603612-01